

Message Text

CONFIDENTIAL

PAGE 01 BRUSSE 05630 212059Z

ACTION OC-06

INFO OCT-01 EUR-12 ISO-00 CCO-00 OCPE-00 OCL-00 SY-05

FBOE-00 A-01 /025 W

-----075300 220348Z /66

R 212043Z MAR 78

FM AMEMBASSY BRUSSELS

TO AMEMBASSY LONDON

SECSTATE WASHDC 5608

AMEMBASSY BONN

C O N F I D E N T I A L BRUSSELS 05630

LONDON FOR ATO; DEPT FOR OC/PE AND A/SY; BONN FOR RCO

E. O. 11652: GDS

TAGS: AFAC, ASEC

SUBJECT: BRUSSELS CCC UPGRADE

REF: (A) BRUSSELS 12150 (B) 77 STATE 262108 (C) 77 BONN

18322 (D) 77 STATE 79674

1. FOLLOWING IS REPORT OF WORK DONE AFTER THE DEPARTURE
OF ATO/SEABEE TEAM:

OLD POWER PANEL REMOVED AND ALL POWER FOR COMMCENTER,
OVERHEAD LIGHTS, TYPEWRITERS, XEROX, ETC., NOW RECEIVED
FROM POWER PANEL LOCATED INSIDE VAULT DOOR. NO
POWER FROM THIS PANEL USED WITHIN PARENT ROOM.

ALL EXTRANEIOUS WIRING, NOT PREVIOUSLY REMOVED BY SEABEE
TEAM, TAKEN OUT.

BLOWER MOTOR AND SOME DUCTING FROM OLD AIRCONDITIONING
SYSTEM REMOVED. ALSO REMOVED OLD METAL FRAME USED TO
SUPPORT OLD AIRCONDITIONER.

CONFIDENTIAL

CONFIDENTIAL

PAGE 02 BRUSSE 05630 212059Z

ALL POWER CABLING AND CONDUITING USED WITH OLD
POWER PANEL REMOVED.

NEW POWER CABLING, WITHOUT CONDUITING, RUN INTO COMMCENTER
FOR LIGHTS, XEROX, TYPEWRITERS, ETC.

ALL WORK WITHIN PARENT ROOM DONE BY CEO BORTER; ALL WORK

IN COMMCENTER DONE BY LOCAL ELECTRICIANS UNDER
SUPERVISION.

2. FOLLOWING WORK STILL TO BE DONE:

FILL IN HOLES IN PARENT ROOM WALLS AND PAINT ENTIRE AREA;
REMOVE AIRCONDITIONING DUCTING GOING FROM PARENT ROOM TO
SECOND-FLOOR ROOF AND SECURE EXISTING HOLE;

INSTALL NECESSARY LIGHTING (110V) IN PARENT ROOM,
PUTTING ALL WIRING IN CONDUITING.

FOR ATO LONDON: WILL ATO SUPPLY THE ABOVE CONDUITING AND
LIGHT FIXTURES PER REF (D).

ABOVE WORK COULD BE ACCOMPLISHED BY RESIDENT CEO
AND SEABEE.

NOW RECEIVE EMERGENCY POWER FOR COMMUNICATIONS FROM NEW
GENERATOR ON ROOF. ALL OTHER COMMCENTER EMERGENCY POWER
RECEIVED FROM EMBASSY GENERATOR. CHAMBERS

CONFIDENTIAL

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 jan 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 21 mar 1978
Decaption Date: 01 jan 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 20 Mar 2014
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1978BRUSSE05630
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: GS
Errors: N/A
Expiration:
Film Number: D780125-0689
Format: TEL
From: BRUSSELS
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1978/newtext/t19780344/aaaablby.tel
Line Count: 77
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: e9dd60c3-c288-dd11-92da-001cc4696bcc
Office: ACTION OC
Original Classification: CONFIDENTIAL
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: CONFIDENTIAL
Previous Handling Restrictions: n/a
Reference: 78 BRUSSELS 12150, 77 STATE 262108, 77 BONN 978
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 18 may 2005
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 3260929
Secure: OPEN
Status: NATIVE
Subject: BRUSSELS CCC UPGRADE
TAGS: AFAC, ASEC
To: LONDON STATE
Type: TE
vdkgvwkey: odb://SAS/SAS.dbo.SAS_Docs/e9dd60c3-c288-dd11-92da-001cc4696bcc
Review Markings:
Sheryl P. Walter
Declassified/Released
US Department of State
EO Systematic Review
20 Mar 2014
Markings: Sheryl P. Walter Declassified/Released US Department of State EO Systematic Review 20 Mar 2014